

ADDENDUM # 002

St. Joseph Catholic School 535 Birchbank Drive Corunna, Ontario

Office and Library Renovations

Project No. 634-CP1714-2

Prepared by:

Randy Wilson Architect Inc.

280 Queens Ave, Suite 1Q London, Ontario N6B 1X3

June 8, 2017

BID CLOSING TIME AND DATE NOTICE

Be advised that the bid close date has been advanced to:

<u>11:00 a.m. on Friday, June 16th. 2017</u>

This addendum forms part of the Contract Bid Documents and amends the original drawings and specifications issued for Bid on June 1st. 2017

TABLE OF CONTENTS

ADDENDUM # 2 (Including cover)	4 Page(s)
Attachments forming part of this addendum.	
Callidus Engineering – Addendum No.1 Drawings: SKE1	2 Page(s) 1 Page(s)
TOTAL PAGE COUNT FOR THIS ADDENDUM	7 Page(s)

PART A – GENERAL

Questions

1.0 Q. Who is currently servicing the DDC control system for the building?

A: Delta by Durell

PART B – SPECIFICATIONS

1.0 BID FORM – Revise to Read

2) <u>CASH ALLOWANCES</u>

REVISE: 2. Include a Stipulated Sum of *One Thousand, Five Hundred Dollars* (\$1,500.00) to cover costs associated with hardware.

3. Include a Stipulated Sum of *Three Thousand Dollars* (\$3,000.00) to cover costs associated with the supply and installation of data cabling and final set up testing. (Wiring Solutions).

2.0 **INSTRUCTION TO BIDDERS:** 1.03 will change to:

1.03 BID DOCUMENTS – Revise to Read:

.3 The Bid proposal shall be delivered to:

St. Clair Catholic District School Board Facilities Services 1930 Wildwood Dr, Bright's Grove Ontario NON 1C0

.4 <u>Bids shall be received no later than 11:00 a.m. on Friday, June 16th. 2017 local time</u> as indicated on the timeclock of the SCCDSB Reception.

Page 4 of 4

Addendum #002

PART C – ARCHITECTURAL DRAWINGS

RESERVED

PART D - STRUCTURAL DRAWINGS

RESERVED

PART E - MECHANICAL / ELECTRICAL DRAWINGS

RESERVED

END OF ADDENDUM # 002



ADDENDUM NO. 1

Attention:	Randy Wilson Architect	Project #:	CE-3660
Address:	280 Queens Avenue, Suite 1Q London, ON.	Project:	St. Joseph School Renovation 535 Birchbank Drive Corunna, ON
Date:	June 8, 2017	Cc.	

Please amend the drawings and specifications for the above noted project as described below. Identify this addendum on the tender form to insure a complete tender form.

1. MECHANICAL

- The mechanical drawings represent two separate tenders. The Work west of the existing 1.1. Gymnasium in the existing change rooms is one tender. The work in the Library and main office area is a 2nd tender. Price the work accordingly as two separate projects. Co-ordinate requirements for pricing with the General Contractor.
- The existing Building Automaton system is a Delta Controls System. Co-ordinate with the 1.2. Board approved Delta Controls trade for modifications to the existing controls to accommodate the new classroom HVAC system and the modifications to the existing controls in the administration offices.
- DWG M1 of 5 1.3.
 - 1.3.1. New Plumbing and Sanitary Layout Co-ordinate the final location of the new AC-101 with the existing storm drain routing in the ceiling space of the corridor.
 - 1.3.2. New Plumbing and Sanitary Layout Re-route the condensate drain from AC-101 to the existing 150mm RWL. Provide new fitting on existing RWL to accept new drain connection. Remove and repair existing insulation as required.
 - 1.3.3. Plumbing and Sanitary Demo Layout Add demolition note 4.
 - 1.3.3.1. Note 4. Disconnect and remove existing shower valves, shower heads and related shower drain from existing shower areas in both existing male and femaie change rooms. [four heads per shower area] Remove existing DCW and DHW piping from existing walls back to the accessible ceiling space. Cap the branch piping at the mains. Re-insulate any exposed piping caused by the demolition.
- DWG M3 0f 5 1.4.
 - 1.4.1. Office Demolition Relocate the existing thermostat located on the north side of the wall to be demolished south of the principal's office. Relocate to the south side of the south wall of the principal's office 24" west of the door into the principal's office. Exact location to be confirmed on site.
 - 1.4.2. Office New Layout Add location of T-stat above.

2. ELECTRICAL

- 2.1. The electrical drawings represent two separate tenders. The Work west of the existing Gymnasium in the existing change rooms is one tender. The work in the Library and main office area is a 2nd tender. Price the work accordingly as two separate projects. Co-ordinate requirements for pricing with the General Contractor.
- 2.2. Drawing E2of 5
 - 2.2.1. Administration Offices Renovation A portion of the existing east wall of the existing administration office is being demolished to accommodate a larger glazing partition between the office and the corridor. Relocate the existing fire alarm pull station, the three gang switch box and switches, the back-box and push button for the barrier free door operator, the back box and key switch for the door lock activation and release, the security system key pad and the FOB proximity reader. Provide pull wires through the block walls from the device boxes to the accessible ceiling space above. Security System wiring and terminations, by Damar Security. Door control system terminations by JPW. Wiring for door controls by electrical trade.
 - 2.2.2. Administration Offices Renovation The existing PA system main control panel is located in the room immediately across the south corridor from the Administration offices. All changes to the P/A system are to be completed by Gordon Ruth, the board's P/A specialists.
 - 2.2.3. Change Rooms Demolition Delete 5 recessed pot lights from the north Change room shower area. [mirror of lighting layout in South Change room shower area.]
- Drawing E3 2.3.
 - 2.3.1. Classroom and Change Rooms Add the following to note 1.... Refer to drawing E2 for existing emergency battery unit locations.
- 2.4. Drawing E4
 - 2.4.1. Add the following text to note 9. 'Relocate the wall mounted speaker that is currently located above the Custodian's Desk in the existing south change room shower area. Extend the wiring as required to suit the new location. Mount the relocated speaker tight to the underside of the new ceiling.'
 - 2.4.2. Provide 2-15A, 1P breakers in existing panel H, circuit 37 and 39. Panel H is a Federal Pioneer, NBLP42B-4LCI rated 225A, 240V, 3PH, 4W. Circuit the receptacles in the new change rooms to circuit 37 and the Custodians office to circuit 39.
 - 2.4.3. Add the following to note 10. 'Circuit to Panel H Cct. 37 [Typical]'
 - 2.4.4. Panel H has 5 existing 1P spaces. Panel A has 10 existing 1P spaces.

3. ATTACHMENTS

3.1. SK-M1, SK-M2, SK-E1

END OF ADDENDUM No. 1

