



**ST. CLAIR CATHOLIC**  
**DISTRICT SCHOOL BOARD**  
*Lighting the Way ~ Rejoicing in Our Journey*

---

***ADDENDUM # 002***

---

**St. Clair Catholic District School Board**

**Holy Trinity Catholic School**  
**60 Lorne Crescent**  
**Sarnia, Ontario**

**Site and Parking Lot Improvement Work**

**Project No. 651-CP1607**

Prepared by:

**Randy Wilson Architect Inc.**  
280 Queens Ave, Suite 1Q  
London, Ontario  
N6B 1X3

May 18, 2016

*This addendum forms part of the Contract Bid Documents and amends the original drawings and specifications issued for Bid on May 9<sup>th</sup>. 2016.*

**TABLE OF CONTENTS**

ADDENDUM # 2 (Including cover) 3 Page(s)

**Attachments forming part of this addendum**

Revised Architectural Drawings 1 sheets

<b>TOTAL PAGE COUNT FOR THIS ADDENDUM</b>	<b>4 Page(s)</b>
---	------------------

**PART A – GENERAL**

**1.1 SITE MEETING/REVIEW completed**

**1.2 TENDER QUESTION(S)**

**Question:**

- 1) Will we be required to remove the existing granulars under the asphalt parking lot being replaced or can we assume that the material is suitable to reuse? Obviously we have to lower and some of the material will have to be disposed of. Drawing states that the minimum thickness of Granular B “300mm” and Granular A “150” is required.

**Answer:** Material is only suitable for reuse is certified by Geotechnical Engineer. Provide granular material as stipulated on Civil Engineers Drawings

- 2) Also for the light bases, can you tell me what the length of the existing poles are ? so I can determine how deep the bases are to be buried?

**Answer:** Pole length can be determined by a site visit. Base is to be placed as per the Civil drawing sketch which gives all of the required dimensions.

**End of Minutes**

**PART B – SPECIFICATIONS**

Not Applicable

**PART C – ARCHITECTURAL DRAWINGS**

**A-010 – COVER SHEET, KEY PLAN**

Revisions for Addendum #2 clouded and noted.

**PART D – STRUCTURAL DRAWINGS**

RESERVED

**PART E – MECHANICAL / ELECTRICAL DRAWINGS**

RESERVED

**PART F – CIVIL ENGINEERING DRAWINGS**

**Architectural Sketches Included**

N/A

**END OF ADDENDUM # 002**

