



ST. CLAIR CATHOLIC
DISTRICT SCHOOL BOARD

Lighting the Way ~ Rejoicing in Our Journey

Addendum #002

Questions & Answers

TENDER NUMBER: 626-CP1916

Universal Washroom Renovation Project

St. Anne Catholic School

183 Snow Ave, Blenheim, ON N0P 1A0

Submission Deadline and Location:

Tuesday, June 25, 2019

2:00:00 PM Local Time

Reception Desk, Catholic Education Centre

420 Creek Street, Wallaceburg, ON N8A 4C4

ADDENDUM #002

A1. Refer to Drawing A101 – Partial Demolition Plan, Partial Floor Plan

.1 Refer to Demolition Plan

Existing Universal Washroom 118 door and hardware to be turned over to owner.

.2 Refer to Demolition Plan & Floor Plan

Remove existing porcelain wall tile dado as required for installation of new door & frame.

Repair wall with matching tile after installation of new door & frame.

A2. Responses to questions received.

QUESTIONS AND ANSWERS

QUESTION 1: There is different coloured rubber base in the different areas in the proposed work area. There is Hunter Green, Brown etc. In the finish schedule it indicates to match existing base, however lately in the past the St. Clair Catholic District School Boards has spec'd Roppe Pinnacle 193 Black/Brown rubber base. My question is would you like to go with the Roppe Pinnacle 193 Black/Brown rubber base in all areas?

ANSWER 1: All new rubber base to be Roppe Pinnacle 193 Black/Brown.

This concludes Addendum #002.